

# Water Quality Association

## Gold Seal Certificate

### Pulsafeeder Engineered Products, Inc

2883 Brighton Henrietta Town Line Road  
Rochester, NY United States

Facility: Pulsafeeder Rochester

Certification Date: May 12, 2017

Authorized By: Tom Spoden

Tom Spoden  
Director of Product Certification

Water Quality Association  
4151 Naperville Road  
Lisle, IL 60532, USA



#0633  
ISO 17065  
Product Certification Body



Revision: 11/05/2015

FORM.12046

This Certificate, or any part thereof, may not be used in a misleading manner and validation of its use is contingent upon the Official WQA web-listing.

# Water Quality Association Official Gold Seal Listing

Granted to the following company:

Pulsafeeder Engineered Products, Inc  
2883 Brighton Henrietta Town Line Road  
Rochester, NY 14623 United States

For the Facility Located at:

Pulsafeeder Rochester  
2883 Brighton Henrietta Town Line Rd.  
Rochester, NY 14623 United States

The WQA Gold Seal Certification Department has issued certification for the following model(s) to the standard(s) below. Only models that appear in the official listing are authorized to bear the WQA Gold Seal.

## NSF/ANSI 61 - 2016: Drinking Water System Components - Health Effects

Eclipse CMD-E02	Eclipse CMD-E05	Eclipse CMD-E12
Eclipse CMD-E125	Eclipse CMD-E25	Eclipse CMD-E75
Eclipse E02	Eclipse E05	Eclipse E12
Eclipse E125	Eclipse E25	Eclipse E75
Eclipse EH02	Eclipse EH05	Eclipse EH12
Eclipse EH125	Eclipse EH25	Eclipse EH75

These Chemical Feeders are certified for use with 50% Ferric Chloride, 12.5% Sodium Hypochlorite, 50% Sodium Hydroxide, 36% Hydrochloric Acid, 34% Hydrofluorosilicic Acid, and 48% Aluminum Sulfate.

Notice: To request any changes to the certified model(s), please request a Change to Certified Product (CCP) form. Examples include any change to the wetted parts or formulations such as supplier or material types, literature, or a change in company name. This list is not all inclusive. Failure to submit documentation regarding changes may result in non-compliance with the standard(s) as well as de-listing of the affected models.